

c/32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

No. F6/DFS/MS/School/WZ/2024/ 673

Dated: 03 / 10 / 2024

To,

The Principal,
SKV, Moti Nagar,
New Delhi – 110015.

Sub: Regarding Issuance of Fire Safety Certificate in respect of SKV, Moti Nagar,
New Delhi – 110015. (School ID-156018)

Sir,

This is in reference to your letter no. SKV/MN/2024/286 dated 31/07/2024, received through outdoor diary no.- 4907 dated 05/08/2024, of this department, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 18/09/2024 in the presence of Sh. Ramjas (Estate Manager) to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said school is running in total four blocks, BLK-1(Main Block) = ground + one upper floor, serving with single staircase having width of 1.78mtr, BLK-2 (Pink Building) = ground + two upper floors(danger building & now not in use), BLK-3(Primary Wing) ground + one upper floor, serving with single staircase having width of 1.53mtr , & BLK-4(Middle Block) ground + one upper floor, serving with two staircase having width of 2X 1.5mtr. The fire safety arrangements such as Fire Extinguishers, sand buckets etc are provided. However the following shortcomings were observed.

1. Single staircase is provided in BLK-1 having width 1.78mtr against requirement of 2X 1.5mtr. .
2. Single staircase is provided in BLK-3 having width 1.53mtr against requirement of 2X 1.5mtr.

In view of above Shortcomings, the application for issuance of fire safety certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, Old secretariat, Delhi – 110054.

11/10/2024