



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F.6/DFS/MS/BP/2024/ 552

Dated: 26/09/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
Dr. S.P.M Civic Centre, JLN Marg,
Delhi-110002.

Sub: Examination of building plans from fire safety point of view in r/o addition and alteration of Somerville School, Lott Carey Baptist Mission in India, Vasundhara Enclave, Chilla, Dallupura, Delhi.

Sir,

Please refer your online request ID 10119217 dated 18/09/2024 on the above cited subject. In this connection it is to inform you that the online building plans have been scrutinized by this department from fire safety point of view and following shortcomings are observed: -

1. Dead end travel distance is not meeting the requirement as per clause 7.8.2 of UBBL 2016/NBC part 4.
2. Alternate exit for art room is not proposed as per clause 7.8.3 of UBBL-2016.
3. Entry to the toilet is not permitted through occupied area.
4. Parking area at ground floor is not segregated with school building as per clause 3.1.11 of Part-IV, NBC-2016.
5. Exit door of canteen is blocked by parking. Further, FCD is not proposed in canteen.

In view of the above, the building plans are hereby rejected.

Yours faithfully

(ATUL GARG)

Director

011-23412025.

BP CB