

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/ 675

Dated: 03/10/2024

To

The Principal,
M/s Udgam Pre-School
Bina Education Society and Daycare,
MOR Pocket 104, Kalkaji Delhi 110019

Sub: Regarding issuance of FSC in r/o M/s Udgam Pre School (Bina Education Society) and Daycare, at MOR Pocket 104, Kalkaji Delhi 110019

Sir,

This has reference to your letter received through Email dated 16/08/2024, on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.09.2024 in the presence of Mr. Ankush Bhardwaj to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There is one staircase having width of 1.50 mtr against the required two staircase having width of 1.50 mtr each.
2. First aid hose reel not provided.
3. Fire fighting pumps capacity 450 LPM not provided.
4. Overhead tank capacity 10,000 ltrs not provided.
5. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.