

c/30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/School/ 668

Dated: 27/09/2024

To,

The Principal,
White Leaf Public School,
Gali no.2- 3, Plot no-89, Pooth Khurd,
Delhi-110039.

Sub: Issue of FSC in r/o White Leaf Public School, Gali no.2- 3, Plot no-89, Pooth Khurd, Delhi-110039.

Sir,

Kindly reference to online e-mail dated 15.07.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.09.2024**, in presence of **Mr. Sunil Sharma (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. All staircases in basement found on one side only, smoke ventilation is not available & basement usage is not clear.
2. Hose reel provided but not functional.
3. Automatic sprinkler system in basement provided but not functional.
4. Terrace Fire pump with capacity 900 LPM provided but not functional.
5. 5000 ltrs Over Head water captive tank provided against the required capacity of 15,000 ltrs.
6. The required exit signage are not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

