

0/57

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 429  
To

Dated: 30/09/2024

The Addl. Commissioner of Police,  
1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s ECHOES** (A Unit of TAUS Venture) located at HS-6, 2<sup>nd</sup> Floor, Kailash Colony Market, New Delhi 110048.

Sir,

This is in reference to with **MHA Portal ID 2024090213500 dated 02/09/2024** on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Parkash (Manager) on 25/09/2024 & observed that the building is comprised of Ground + Mezz. + Three upper floor. During the course of inspection, the following shortcoming observed were noticed:-

1. There are two staircases having width of 1.50 mtr & 1.40 mtr against the required width of 1.50 mtr each. The second staircase through bar area, which needs to be removed.
2. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

9/11/24