

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 03/10/2024

No. F.6/DFS/MS/School/2024/SZ/ 678

To

The Principal,
M/s Malviya Public School, at
T-55, Khirki Extension, Malviya Nagar,
New Delhi 110017.

Sub: Regarding issuance of FSC in r/o M/s Malviya Public School, at T-55, Khirki Extension, Malviya Nagar, New Delhi 110017.

Sir,

This has reference to your letter received through outdoor diary no 5834 dated 30/08/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.09.2024 in the presence of Ms. Rita Chabra (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two staircase having width of 1.40 mtr & 1 mtr against the required two staircase having width of 1.50 mtr each.
2. First aid hose reel not provided.
3. Automatic Sprinkler system not provided in the basement.
4. Fire fighting pumps capacity 900 LPM not provided.
5. Overhead tank capacity 15,000 ltrs not provided.
6. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.