



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2024/WZ/ 670

Dated:

30/09/2024

To,

The Principal,
Nigam Pratibha Vidyalaya,
HU Block, Pitampura,
Delhi-110034.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Nigam Pratibha Vidyalaya located at HU- Block, Pitampura, Delhi- 110034.

Sir,

This has reference to your email id dated 19.09.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 24.09.2024 to see the to see the compliance of the requisite fire safety measures. Smt. Harvinder Kaur (In-charge) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and First floor and MP Hall at Ground floor. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. The door width of MP Hall found 1.4 m and 1.38 m against the required width of 1.5 m each.
2. Electrical meter and panel installed under the staircase has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

PH. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.