

453

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

NO. F6/DFS/MS//SZ/2024/ 556

DATED: 01/10/2024

To,

Sh. Umesh Yadav, AIG (SPU-III)  
Residential cum Training Complex for SPG  
Plot No 21, Sector – 21, Dwarka,  
New Delhi – 110077.

**Subject: Renewal of Fire Safety Certificate in r/o Residential cum Training Complex for SPG Located at Plot No 21, Sector – 21, Dwarka, New Delhi – 110077, Residential Blocks Type IV & Type V.**

Sir,

Please refer to Form J, dated nil on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 23/09/2024 in the presence of Sh. Vimal Prakash Shina (SO) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Staircase found partially blocked.
2. Door closers of FCD found missing at some places.
3. Pressurization system found nonfunctional on auto mode.
4. Terrace pump found nonfunctional on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.

Yours faithfully,

(Atul Garg)  
(Director)

Delhi Fire Service

Copy to:-

1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.