

c/04

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/ 687

Dated: 08/10/2024

To,

The Principal,
Adarsh Public School,
A-48, Naresh Enclave,
Jain Colony,
Delhi-110039.

Sub: Issue of FSC in r/o Adarsh Public School, A-48, Naresh Enclave, Jain Colony Delhi-110039.

Sir,

Kindly reference to online e-mail dated 12.08.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 20.09.2024, in presence of **Mr. Rajesh Bhardwaj (Owner)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of staircase is 0.96 mtr. against the required width of two staircases of 1.5 mtr each
2. First Aid hose reel not provided.
3. Terrace Fire pump with capacity 450 LPM not provided.
4. Over Head water captive of 10,000ltr tank not provided.
5. Exit signage not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

8u
04