

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2024/SZ/2231
To

Dated: 03/10/2024

The Authorised Signatory,
M/s Fortune Institute of International Business,
Plot No -5, Rao Tula Ram Marg,
Vasant Vihar, New Delhi -110057

Sub: Regarding issuance of FSC in r/o M/s Fortune Institute of International Business,
Plot No -5, Rao Tula Ram Marg, Vasant Vihar, New Delhi -110057.

Sir,

This has reference to your letter no nil dated 24/08/2024, received through outdoor diary no 5897 dated 02/09/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.09.2024 in the presence of Mr. Manish (Registrar) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Basement is being used for library and reading purposes.
2. Temporary structure at terrace level, which need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature]

[Handwritten notes]
shobha
24/09/2024