

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/ 689
To

Dated: 08/10/2024

The Principal,
M.C.D Pratibha School,
Harkesh Nagar- II, (CZ)
New Delhi -110020.

Sub: Reg. renewal of Fire Safety Certificate in r/o M.C.D Pratibha School, at Harkesh Nagar- II, (CZ) New Delhi -110020.

Sir,

This is in reference with your Email Dated 21/09/2024 on the subject cited above. In this regard, it is informed you that the school premises have been inspected by officer concerned of this department on 01.10.2024 in presence of Mr. Anil Kumar to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. First Aid Hose reel provided but found not working.
2. Terrace level fire fighting pump capacity 450 LPM provided but found not working.
3. The Exit signage found removed at some places.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE