

c/n



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 682

Dated: 04/10/2024

To,
The Principal
Sarvodaya Kanya/Bal Vidyalaya No-02
A-Block, Jahangirpuri, Delhi-110033.

Sub:- Regarding renewal of fire safety certificate in r/o Sarvodaya Kanya/Bal Vidyalaya No-02 (School ID No- 1309253-54) located at A-Block, Jahangirpuri, Delhi-110033.

Sir,

Please refer to your letter No. SKV/ABLK/JP/2021/421 dated: 19.09.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 28.09.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Sh. Satish Kumar (Estate Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Some fire extinguisher found not functional at the time of inspection.
2. Hose reel hose is provided but not functional and some nozzles found missing.
3. Terrace level fire pump capacity of 450 LPM is provided but found not functional.
4. Terrace level fire water tank capacity of 10,000ltr being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
5. Exit signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Anil Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.