

c 64

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/2024/NDZ/College/336

Dated 03/10/2024

To,

Mr. Narinder Singh (Secretary General),
The Indian Society of International Law,
V.K. Krishna Menon Bhawan, 9,
Bhagwan Dass Road, New Delhi-01.

**Sub:- Regarding issuance of FSC in r/o M/S The Indian Society of International Law,
V.K. Krishna Menon Bhawan, 9, Bhagwan Dass Road, New Delhi-01.**

Sir,

This has reference to your letter no. ISIL/Admn./2024/07 dated 04.09.2024, on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 24.09.24 in the presence of Mr. Gaurav and the following shortcomings were observed:

1. 4th floor & ground floor is under renovation and all firefighting systems including fireman's switch found removed.
2. The sanctioned building plan is required to be submitted to ascertain the fire safety arrangements and all around road to the building and use of basement as Gym and library is running in the basement having single exit.

Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Chief Architect, NDMC, Palika Kendra, New Delhi.