

01/25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/GH/2024/SZ/ 622

Dated: 03/10/2024

To,

The Joint C.P. (Lic.),  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.

**Sub: -Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M/s. Vashist & Associates guest house at J-35, Ganga Ram Vatika, Chaukhandi Road, Tilak Nagar, New Delhi- 110018.**

Sir,

Please refer to online application ID No. 2024091514285 dated 17.09.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid guest house building on dated 26.09.2024 in the presence of Sh. Anil Vashist (Owner), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the guest house building comprised of basement, stilt, upper ground plus three upper floors, and have following shortcomings: -

1. A Fitness Gym found running in basement instead of storage.
2. Fire Check Doors also removed from back side at some places.
3. Hose reels/hydrant system found provided but not functional.
4. Sprinkler found removed from stilt area and covered by tin shed.
5. Terrace pump of 450 LPM provided but found not functional.
6. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, management of the guest house may be requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running guest house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Anil Garg)  
Director

Delhi Fire Service  
Chaukhandi Road, Tilak Nagar, New Delhi- 110018.

Copy to: -

1. The Owner/occupier, M/s. Vashist & Associates guest house at J-35, Ganga Ram Vatika, Chaukhandi Road, Tilak Nagar, New Delhi- 110018.
2. Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027.

: - for information regarding use of basement.