

c/32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/SZ/2024/ EN | 427

Dated: 30/09/2024

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Renewal of Fire Safety Certificate from fire safety point of view in r/o Ms W V A Bien (A unit of NGH Hospitalities Pvt. Ltd.) Located at Plot No. B-32, 3rd floor, Pusa road, Old Rajinder Nagar, Karol Bagh, New Delhi.


Sir,

Please refer to online application No. 2024083013378, dated-04/9/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officers concerned from this department on 23/09/2024 in the presence of Sh. Nitin from fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Staircases found partially blocked.
2. Fire extinguishers found removed.
3. Hose reel hose & hydrants found nonfunctional.
4. Automatic fire detector system found nonfunctional.
5. MOEFA & PA system found nonfunctional.
6. Terrace pump found nonfunctional.
7. Main pump & stand by pump of capacity 2280 lpm found replaced by two electrical pump of 1200 lpm and also found nonfunctional.
8. Exit signage found removed.
9. Restaurant activities are noticed at 4th floor without taking any fire safety provisions.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.


(Atul Garg)
Director
Delhi Fire Service
23/9/24

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, Ms W V A Bien (A unit of NGH Hospitalities Pvt. Ltd.) Located at Plot No. B-32, 3rd floor, Pusa road, Old Rajinder Nagar, Karol Bagh, New Delhi.