



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



Dated: 09/10/2024

No. F6/DFS/MS/2024/CC/342

To

Sh. Manish Singh
At Plot No-1605, Ground Floor,
Outram Line, Kingsway Camp, Delhi-09.

Sub: - Regarding issuance of Fire Safety Certificate in r/o EG Classes (Coaching Centre) Plot No-1591, Ground Floor, Outram Line, Kingsway Camp, Delhi-110009.

Sir,

Please refer to your letter received through online e-mail dated 25.09.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 28.09.2024 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Manish Singh was also present at site. During the course of the inspection it is observed that the building is comprised of ground & 02 upper floors, but coaching centre running at ground floor. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Hose reel hose is not provided.
2. Terrace level fire pump capacity of 450lpm is not provided.
3. Terrace level fire water tank capacity of 10, 000ltr is not provided.
4. Exit & floor signage's is not provided at strategical location in the building.
5. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of educational building (coaching centre) is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Executive Engineer (Bldg.)-I, Rajpura Road, Civil Line Zone, Delhi.

5/10/24
[Signature]