



75
आज़ादी का
अमृत महोत्सव

C/192

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/Hospital/2024/2269

Dated: 10/10/2024

To,

Sh. Nitin Kumar Gupta
Assistant Engineer (Civil), PMD, Branch,
ESIC Model Hospital,
Ring Road Basai Darapur,
New Delhi- 110015.

**Sub - Regarding Issuance of Fire Safety Certificate in R/o Building, E.S.I.C. Model
Hospital, Basaidarapur, New Delhi-110015.**

Sir,

Please refer to your letter no. DM(H)A-13/14/11/Misc.(UPRNN-NKG)/2017/Estate dated 21/08/2024, on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 30/09/2024 in the presence of Sh. Nitin Kumar Gupta and observed that the shortcomings already communicated by this department vide letter No. F6/DFS/MS/Hospital/2022/705 dated 29/03/2022, F6/DFS/MS/Hospital/WZ/2022/101 dated 17/01/2023 & F6/DFS/MS/Hospital/WZ2023/366 dated 27/02/2023, is still not complied.

In view of above, the application for issuance of fire safety certificate is not considered at this stage & rejected. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to:

1. The Medical Superintendent, ESI Hospital, Basaidarapur, New Delhi.
2. The Director, (Health Service), GNCT of Delhi, Near Karkardooma Court, New Delhi.
3. The Ex. Engineer, (Bldg), HQ, 8th floor, Civic Centre, MCD, New Delhi.

r/c
07/10/2024



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Hospital/WZ/2023/ 366

Dated: 27/02/2023

To,

The Unit Incharge,
UPRRN, Elect. Unit,
ESI Hospital Complex,
Basaibarapur, New Delhi.

Subject: - Regarding Issuance of Fire Safety Certificate in R/o OPD Block, E.S.I.C. Model Hospital, Basaidarapur, New Delhi.

Sir,

Please refer to your Email dated 27/01/2022 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 10/02/2023 in presence of Smt. Manmohan Bhandari to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/Hospital/2022/705 dated 29/03/2022 & F6/DFS/MS/Hospital/WZ/2022/101 dated 17/01/2023.


The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	Fire Check doors have not been provided in lift lobbies.	Not Rectified
2.	Pressurization is not provided in lift lobbies & lift well.	Not Rectified
3.	Exit Sinages are not provided.	Not Rectified
4.	Fire Control Room is not provided by the management of the hospital.	Not Rectified
5.	Floor plan is not displayed in prominent place.	Not Rectified

In view of above Shortcomings the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director

o/c 
23/2/2023

Copy To: -

1. The Medical Superintendent, ESI Hospital, Basaidarapur, New Delhi.
2. The Director, (Health Service), GNCT of Delhi, Near Karkardooma Court, New Delhi.
3. The Ex. Engineer, (Bldg), HQ, 8th floor, Civic Centre, MCD, New Delhi.