

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

C/83

No. F6/DFS/MS/2024/ 570

Dated: 10/10/2024

To,

The Assistant Engineer (E),
Judiciary Electrical Sub-Divison-V,
PWD, New Delhi District court
Rouse Avenue. DDU Marg,
New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in r/o New Delhi District Court Complex at Rouse Avenue, DDU Marg, New Delhi.

Sir,

This has reference to your letter No. 01/AE(E)/JESD-V/NDDC/2024-25/150 dated 09/09/24 on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 01/10/24 in the presence of Sh. Sandeep Kumar AE (E) and the following shortcomings were observed:-

1. Pressurization of staircase and lift shaft/lobby found nonfunctional
2. Detectors found non functional at some places.
3. Hose reel at upper floor found nonfunctional.
4. Diesel pump found nonfunctional

In view of above shortcomings, the Fire safety certificate cannot be renewed. Therefore, you are requested to rectify the above shortcomings as earliest.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to

1. The District Judge, New Delhi
District Court Complex, DDU Marg, New Delhi.
2. The Commissioner, MCD, Civic Centre, New Delhi.

:-For Information Please.