

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F.6/DFS/MS/ BP/2024/ 567

Dated: 09/10/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
Dr. S.P.M Civic Centre, JLN Marg,
New Delhi-110002.

Sub: Clearance from fire safety point of view in r/o Plot No. 33 in class C, North West Avenue Road, the approved colony, Punjabi Bagh west, New Delhi.

Sir,

Please refer your ID No. 10119473 dated 28/09/2024 on the above cited subject. In this connection, this is to inform you that the online building plans in respect of proposed building have been scrutinized by this department from fire safety point of view. Following shortcomings have been observed: -

1. Fire pump room is not proposed as per clause 5.1.2.2 of NBC part,4 2016.
2. The exit discharge is proposed as per clause 4.4.2.4.3.1 of NBC part,4 2016.
3. The shaft is opening at every floor which is not compartmented as per clause 4.5.1 of NBC part-4,2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Singh)
Director
011-23414000
w/ CTS