

C-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/SZ/2024/ 713

Dated 16/10/2024

To,

The HOS,
Adarsh Secondary School,
D-Block, Vikas Puri, New Delhi-110018.

Sub: - Regarding renewal of fire safety certificate in r/o Adarsh Secondary School located at D-Block, Vikas Puri, New Delhi-110018.

Sir,

Please refer to your letter No. A.Sec.S/24 dated 10.09.2024, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department from safety point of view on dated 08.10.2024 in presence of Smt. Sadhna Bhardwaj (Principal).

During the course of inspection found that the school building comprised of basement, ground plus one upper floor. However, the following shortcomings have been observed: -

- 1 First Aid hose reels found provided but not functional.
- 2 Sprinkler provided in basement found not functional.
- 3 Terrace Fire pump Capacity of 450 LPM found provided but not functional.
- 4 Water storage tank found broken.
- 5 Exit signage found removed.
- 6 School activity found running in the basement instead of storage. Advised to submit sanction basement building plan of school.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

- 1 The Director of Education, GNCT of NCT of Delhi, Old Secretariat- 110054.
- 2 Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027.

: - for information regarding use of basement.