



No. F6/DFS/MS/BANQUET/NDZ/2024/ 119

Dated: 10/10/2024

To,

The Joint Commissioner (Lic.),
1st floor Police Station Defence Colony,
New Delhi - 110024.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Ambika Place located at B - 3/3
Bhajanpura Main Wazirabad Road, Delhi - 110053.**

Sir,

This has a reference to MHA Application No. 202492014468 dated 22/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/10/2024 in the presence of Mr. Shashi Kant Aggarwal (Owner) and observed that building comprised of Basement, Mezzanine floor, ground plus three upper floors. **(Banquet hall is running on first & second floor only).**

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.30 & 1.10 meter are provided instead of required width of 1.50 meters each.
2. Fire check door found removed.
3. Exhaust fan found removed in basement.
4. First-Aid-Hose Reel provided but not functional.
5. Automatic Fire Detection and Alarming System provided but not functional.
6. MOEFA not provided.
7. Automatic Sprinkler System provided but not functional.
8. Internal Hydrant provided but not functional.
9. Fire pump of 450 LPM provided but not functional.
10. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

OK @ DELHI FIRE SERVICE

Copy to:-

1. The Manager, Ambika Place located at B - 3/3 Bhajanpura Main Wazirabad Road, Delhi - 110053.
2. The Joint Commissioner of Police (Lic.), 1st Floor, Police Station, Defence Colony, New Delhi -