



c/89



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH//2024/WZ/ 443

Dated: 10/10/2024

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Green Lounge Restaurant located at Ground floor, 39-43, Aggarwal City Mall, Plot No. 5, Road No. 44, Pitampura, New Delhi- 110034.

Sir,

This has reference to your online application received through MHA portal vide ID- 2024042205833 dated 21/09/2024 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 03/10/2024 in presence of Sh. Rattan Singh. Following shortcoming were observed at the time of inspection.

1. First aid hose reel found provided but not functional.
2. Detectors found provided but not functional.
3. MOEFA found provided but not functional.
4. P.A. System found provided but not functional.
5. Pumping system not found in auto mode.


In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000


8/10/24

Copy to:-

1. The Dy. Health Officer, Keshavpuram Zone, A-1, Public Health Department, MCD, Keshavpuram, New Delhi-110035.
2. The owner/ occupier, M/s Green Lounge Restaurant, Ground Floor, 39-43, VPlot No. 5, Road No. 44, Pitampura, Delhi- 110034
3. MHA Online ID No. 2024042205833.