

c/65



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/449

Dated 14 / 10 / 2024

To
The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, PS Defence Colony,
New Delhi 110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s GUNG THE PLACE, (A Unit of YJ EXIM & Restaurants Pvt. Ltd) located at D-1/B, GF, FF & SF Green Park, New Delhi 110016.

Sir,

This has reference to with **MHA Portal ID 2024091914395 dated 19/09/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.10.2024 in the presence of Mr. Moses (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of Basement, ground + 02 upper floors. The restaurant is running at Ground, First & Second floor only. During the course of inspection. The following points were observed:

- 1 First Aid Hose reel provided but found nonfunctional.
- 2 Terrace level Fire Pump capacity of 450 LPM provided but found nonfunctional.
- 3 Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

