

C-474

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001.**

NO. F.6/DFS /MS/NDZ/2024/ 573

Dated: 11/10/2024

To,

Ms. Seema Khurana,  
Assistant Manager (EMD),  
ITPO, Pragati Maidan,  
New Delhi.

**Sub: Application for renewal of Fire Safety Certificate in respect of India Trade Promotion Organisation (ITPO), a Govt. of India's Enterprise, Ministry of Commerce & Industry, Hall Nos. 2, 3, 4, 5 ( GF and FF and Mezzanine floor) at Pragati Maidan, New Delhi.**

Sir,

This has a reference to your letter no. 145-ITPO(12)/BDD/2018 dated 02.09.2024 & received DFS diary no. 6435 dated 12.09.2024, on the subject cited above. In this connection it is to inform you that the site was inspected by ADO/CC & DO/CD in presence of Sh. Amit on dated 03.10.2024 and the following shortcomings were observed:-

1. Smoke curtain were found nonoperational to achieve the complete compartmentation of halls.
2. Pressurization of staircases and lift lobbies found nonfunctional.
3. Smoke Management found nonfunctional.
4. Detectors found non functional
5. MOEEFA found nonfunctional.
6. Glass of Fire check doors at some places found broken.
7. Water curtain in basement found non- functional.

Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department at the earliest. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:

1. The GM, ITPO, Pragati Maidan, New Delhi.