

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/ 691

Dated: 09/10/2024

To

The Principal,
M/s Johns International School,
Plot No 92, G-Block, Phase-6,
Aya Nagar, New Delhi 110047.

Sub: Regarding issuance of FSC in r/o M/s Johns International School located at Plot No 92, G-Block, Phase-6, Aya Nagar, New Delhi 110047.

Sir,

This has reference to your letter no nil dated 17/09/2024, received through outdoor diary no 6765 dated 20/09/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04.10.2024 in the presence of Mr. Bessie Mathew to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There is one staircase having width of 1 mtr against the required two nos of staircase having width of 1.50 mtr each.
2. Corridor width is less than 1.50 mtr.
3. First Aid hose reel not provided.
4. Automatic sprinkler system not provided in the basement.
5. Terrace level fire fighting pumps capacity 900 LPM not provided.
6. Overhead tank capacity 15000 ltrs not provided.
7. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, old Secretariat New Delhi 110054.