

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/ 441

Dated 09/10/2024

To

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, PS Defence Colony
New Delhi 110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Madam Chutney (A unit of Food Essentials Hospitality) located at M-20 First Floor, M Block Market, GK-2, Delhi -110048

Sir,

This has reference to your **MHA Portal 2024091414274 dated 14/09/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 30.09.2024 in the presence of Mr. Sushant (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at First Floor of the building. During inspection, following points were observed:

- 1 Electrical Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
- 2 Underground tank for firefighting capacity 1,00,000 ltrs not provided
- 3 Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

o/w c