

215

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 446

Dated: 10/10/2024

To,
The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Renewal of Fire Safety Certificate from fire safety point of view in r/o Ms Evva Restaurant (A unit of salt & straw LLP.) Located at Plot No. 30B, 3rd floor, Old Rajinder Nagar, Pusa Road, New Delhi.

Sir,
Please refer to online application No. 2024091214184, dated-12/9/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 08/10/2024 in the presence of Sh. Surender (Guard) from fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. One Staircase found partially blocked.
2. Hose reel hose & hydrants found nonfunctional.
3. MOEFA found nonfunctional.
4. Terrace pump found nonfunctional and main valve found closed
5. Main pump & stand by pump & jockey Pump found nonfunctional. The discharge capacity of all pumps must be informed.
6. Restaurant activities are noticed at terrace without taking any fire safety provisions.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.

(Anul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, Ms Evva Restaurant (A unit of salt & straw LLP.) Located at Plot No. 30B, 3rd floor, Old Rajinder Nagar, Pusa Road, New Delhi.