

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ 633

DATED: 09/10/2024

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/s MSK Residency Guest House Located at C-912, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floors Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077.**

Sir,

Please refer to online application No. 2024091114114, dated 11-09-2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 04/10/2024 in the presence of Mr Kul Bhushan Sharma from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire check doors not provided at 2<sup>nd</sup> floor.
2. CO detectors not provided in newly added rooms.
3. Exit signage's not provided at some places.
4. The staircase area at 1<sup>st</sup> floor must be segregated from floor area.

In view of the above shortcomings Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Atul Garg)  
Director,  
Delhi Fire Service.

Copy to:-

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement
2. The Manager, M/s MSK Residency Guest House Located at C-912, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floors Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077.