



Dated: 16/10/2024

No. F6/DFS/MS/School/NDZ/2024/ 711

To,

The Principal,
M.S.W Public School
B - 369, Gali No. 5, Babu Nagar,
karawal Nagar, Delhi - 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o M.S.W Public School located at B - 369, Gali No. 5, Babu Nagar, karawal Nagar, Delhi - 110094.

Sir,

This has a reference to your Outdoor Dairy No. 6999 dated 25.09.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 08/10/2024 in the presence of Mr. Rohan Malik (Manager) and observed that building comprised of Ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. One Staircase of width 1.40 meters are provided against requirement of two width 1.50 meters each.
2. Fire Extinguishers not provided.
3. First-Aid-Hose Reel at each floors not provided.
4. Fire pump of 450 LPM not provided.
5. Over head water storage tank of 10,000 liters capacity is required exclusively for firefighting is not provided.
6. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Manager, M.S.W Public School located at B - 369, Gali No. 5, Babu Nagar, karawal Nagar, Delhi - 110094.