

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/ 700

Dated: 11/10/2024

To

The Principal,  
RKS Vidya Niketan,  
Block-9/1A, Kalkaji Extension,  
New Delhi-110019

Sub.: - Renewal of Fire Safety Certificate in r/o RKS Vidya Niketan, Block-9/1A, Kalkaji Extension, New Delhi-110019

Sir,

This has reference to your letter no 2024-25/083 dated 20.09.2024 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 30/09/2024 in the presence of Mr. Ashok Kumar Mittal (Principal). During the inspection it was observed that school is comprised of Ground plus two upper floors, Except Auditorium. The shortcomings observed are as below.

1. First Aid Hose Reels provided but found not working.
2. Automatic Sprinkler system provided but found non-functional in the basement.
3. Terrace level pump capacity 900 LPM provided but found not working.
4. Exit signage found removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054