

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2024/WZ/ 718

Dated: 21/10/2024

To,

The Principal,  
Govt. Girls Sr. Sec. School,  
Siraspur, Delhi-110042.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School located at Siraspur, Delhi- 110042.

Sir,

This has reference to your e mail id dated 27/09/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 08.10.2024 to see the compliance of the requisite fire safety measures. Smt. Nishi Lata (In-charge) was present at the time of inspection.

During the course of inspection it was observed that building is comprised of Ground plus three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First Aid Hose reels found provided but not functional.
2. Terrace level pump found provided but not functional.
3. Temporary rooms found constructed under the staircases which have to be removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.

16/10/24