



75
Azadi Ka
Amrit Mahotsav

C/26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/2345

Dated: 22/10/2024

To

The Executive Engineer (E),
Safdarjung Hospital Electrical Division,
Central Public Works Department,
Safdarjung Hospital Complex,
Ring Road, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o Gynae Block, Safdarjung Hospital Complex, Ring Road, New Delhi-110029

Sir,

This is with reference to your office letter No. 19(1)/DB/SJHED/2024-25/1337 dated 23/09/2024, received through outdoor diary No. 6989 dated 25/09/2024, on the subject cited above. In this connection, the premises was re-visited by the officer concerned of this department on 11/10/2024 to verify the compliance of shortcomings communicated vide this office letter No. F.6/DFS/MS/Hospital/SZ/2024/99 dated 05/03/2024 in the presence of Mr. Vivek Kumar Gupta (JE-E) and observed that the shortcomings have not been rectified as yet.

In view of the above, the application for renewal of fire safety certificate is rejected. You are again requested to rectify the shortcomings in toto under intimation to this department for further consideration in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital, Ring Road, New Delhi-110029



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/99

Dated: 05/03/2024

To

The Executive Engineer (E),
SJHED Central Public Works Department,
Safdarjung Hospital Complex,
Ring Road, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Gynae Block, Safdarjung Hospital Complex,
Ring Road, New Delhi-110029**

Sir,

This has reference to the email dated 19/01/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 26/02/2024 in the presence of Mr. Vivek Gupta (JE/Elect). During the course of inspection, the shortcomings observed are as below.

1. The stairs/escape route at 3rd floor found encroached/blocked with material/machines.
2. The first aid hose-reel found non-functional and some without shut off nozzle.
3. Automatic fire detection & alarming system found non-functional at some places.
4. MOEFA/MCPs found provided but non-functional.
5. Some yard hydrants found non-functional and in bad condition also some hose-boxes without branch & hoses.
6. The fire pumps found removed/under repair (Common Pump Room).
7. Fireman's switch found defective/non-functional.
8. Lift signage found removed.
9. Some escape route/corridor found totally blocked with lock & chain.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(APUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital, Ring Road, New Delhi-110029