

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/ 591
To

Dated: 18/10/2024

The Joint commissioner of Police,
Lic Branch, 1st Floor, PS Defence colony,
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Honestly Italian Pvt Ltd
(Unit of Better Together Family Trust) located at Plot No 2, Ambience Mall,
Nelson Mandela Marg, Vasant Kunj, New Delhi-110070

Sir,

This has reference with **MHA Portal ID 2024092014463 dated 20/09/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.10.2024 in the presence of Mr. Shankar to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There is only one exit provided against the required two exit ways having width of 1.50 mtr each. The travel distance of dead end is more than of 30 mtrs of the restaurant.
2. Sprinkler system not provided in the part portion.
3. Exit signage not provided.

The same observations has already been issued and communicated earlier by this department vide letter of even no 513 dated 09/09/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/m e/