



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Pet1/2024/SZ/ 587

Dated: 18 / 10 / 2024

To

Authorized Signatory,
M/s Luxmi Super Services,
(Retail Outlet of HPCL Petroleum),
Laxmi Bai Nager, Opp. INA Market,
New Delhi-110023

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Luxmi Super Services (Retail Outlet of HPCL Petroleum) Laxmi Bai Nager, Opp. INA Market, New Delhi-110023.

Sir,

This is with reference to your letter received vide outdoor diary No. 5957 dated 03/09/2024. In this connection, the said premises was visited by the officer concerned of this department on 08/10/2024 to verify the status of fire safety arrangements in presence of Sh. Nityanand Dobhal (Manager). During the inspection, following shortcomings have been observed: -

1. No smoking signages (In Hindi & English) found removed.
2. CNG facility is running without final clearance/NOC from this department as per condition mentioned at serial No. 9 of letter issued for clearance of installation of CNG facility vide No. F.5/(3A)/DFS/2010/223 dated 21/07/2010.

Keeping in view the above shortcomings, application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire & life safety provisions shall be at the risk and liability of the owner/occupier. You are advised to apply for clearance of CNG facility from this department through authority concerned.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi-110049
2. The Medical Officer of Health, New Delhi Municipal Council, Sansad Marg, Palika Kendra, New Delhi-110001