



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

C/17



No: F.6/DFS/MS/School/2024/WZ/ 722

Dated: 22/10/2024

To,

The Principal,  
M.C. Primary Girls School,  
B-1, J.J. Colony, Bawana,  
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary Girls School, B-1, J.J. Colony, Bawana, Delhi- 110039.

Sir,

This has reference to your email id dated 04.10.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 14.10.2024 to to ascertain the availability and operability of the fire prevention and fire safety measure, Smt. Sarita (In-charge) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and First Floor. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. The road width found 4.5 m against the required width of 6 m.
2. Only 2 fire extinguishers found provided against the requirement of 4 fire extinguishers.
3. First aid hose reels found not provided.
4. Terrace level pump of 450 lpm capacity found not provided.
5. Overhead tank of 10,000 ltrs capacity exclusively for fire pump found not provided.
6. Exit signage's are not provided.
7. Electrical panel and electric meter installed under the staircase has to be removed to a safer place or been segregated.


You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

  
(Atul Garg)  
Director  
Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.

  
21/10