



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2024/WZ/ 727

Dated: 23/10/2024

To,

The Principal,  
M.C. Primary Co-ed School,  
J.J. Haiderpur, Delhi-110088.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary Co-ed School, J.J. Haiderpur, Delhi- 110088.

Sir,

This has reference to your email id dated 23.09.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 18.10.2024 to see the to see the compliance of the requisite fire safety measures. Smt. Manila Verma (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Two upper floors. Your request for renewal of FSC is rejected due to the following shortcomings:-

1. Width or corridor found reduced to 1 m due to the large hose reel boxes placed inside the corridor.
2. First aid hose reels nozzle found missing.
3. Terrace level pump of 450 lpm discharge capacity found provided but not functional.
4. Overhead tank of 2,000 ltrs capacity found provided against the required 10,000 ltrs capacity exclusively for fire pump.
5. Exit signage's found removed.
6. Electrical panel and electric meter installed under the staircase have to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)  
Director  
Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.