



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/27



No: F.6/DFS/MS/School/2024/WZ/ 720

Dated: 21/10/2024

To,

The Principal,
MC Primary School,
EU Block, Pitampura,
Delhi-110034.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MC Primary School located at EU- Block,
Pitampura, Delhi- 110034.

Sir,

This has reference to your email id dated 08.10.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 18.10.2024 to see the to see the compliance of the requisite fire safety measures. Smt. Sarita Gauba (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and First floor and MP Hall at Ground floor. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. The door width of MP Hall found 1.45 m and 1.10 m against the required width of 2 m each.
2. Exit signage's found not provided.
3. Electrical meter and panel installed under the staircases have to be removed to a safer place or been segregated.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Gang)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.

18/10