

e114

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/college | 348

Dated: 22/10/2024

To,

Dr. N. Malati  
Delhi Institute of Advanced Studies,  
Plot No-6, Sec-25,  
Delhi-110085.

**Sub:** Issue of FSC in r/o Delhi Institute of Advanced Studies, Plot No-6, Sec-25, Delhi-110085.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 5808 dated 30.08.2024 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 07.10.2024, in presence of **Sh. Prahalad Singh** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace fire pumps were not found in auto mode.
2. Staircase at terrace found altered and alternate exit is not accessible.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htp://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htp://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Anil Garg)  
DIRECTOR

Ph; 011-23414000

Ou  
94