

C/27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/2024/ 592

Dated 21/10/2024

To,

Sh. N.K. Gaur (Fire Officer),
New Delhi Municipal Council,
Palika Kendra, New Delhi.

Sub:- Regarding renewal of FSC in r/o Talkatora Indoor Stadium at New Delhi.

Sir,

This has reference to your Mail id <fo@ndmc.gov.in> dated 23.09.2024, on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 11/10/2024 in the presence of Sh. Mahinder Shokeen, and the following shortcomings were observed:-

1. Detectors found nonfunctional.
2. Hose reel found nonfunctional.
3. Hydrants & yard hydrant found nonfunctional.

In view of above, case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.