

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 590

Dated: 18/10/2024

To

The Joint commissioner of Police,  
Lic Branch, 1<sup>st</sup> Floor, PS Defence colony,  
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Think9 Retail Pvt Ltd  
(Unit of Think9 Digital Consumer Brands Pvt Ltd) located at Plot No 2,  
Ambience Mall, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070

Sir,

This has reference with **MHA Portal ID 2024093015022 dated 30/09/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.10.2024 in the presence of Mr. Santosh to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There is only one exit provided against the required two exit ways having width of 1.50 mtr each. The travel distance of dead end is more than of 30 mtrs of the restaurant.
2. Sprinkler system not provided in the part portion.
3. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE