

C/78

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 593

DATED: 21/10/2024

To,

The President,
Vijay CGHS Ltd.
Plot No. 17, Sector - 18A, Dwarka,
New Delhi - 110078.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Vijay CGHS Ltd. Located at Plot No. 17, Sector - 18A, Dwarka, New Delhi - 110078.

Sir,

Please refer to your Email dated-26/09/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 15/10/2024 in the presence of Mr.Shakil from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Staircases found partially blocked & locked at terrace.
2. Hose Reels & Hydrants system found nonfunctional.
3. MOEFA & PA system found nonfunctional.
4. Automatic sprinkler system found nonfunctional in basement.
5. All the Pumps at terrace level found nonfunctional & main valve found closed at terrace.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.

Copy to:-

(Atul Garg)
Director
Delhi Fire Service

ok

The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi