

C14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2024/456

Dated: 16./10/2024

To

The Manager,  
M/S DASAPRAKASH ( A unit of Das kitchen )  
H-36, Mezzanine Floor, Outer Circle,  
Connaught Place, New Delhi.

Sub: Regarding grant of FSC in r/o M/S DASAPRAKASH ( A unit of Das kitchen ) located at, H-36, Mezzanine Floor, Outer Circle , Connaught Place, New Delhi -1.

Sir,

This has reference to ID No 2024092114556 dated 21/09/24, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 09/10/2024 in the presence of Mr. Ajay , **Manager** and the following shortcomings were observed:-

1. Hose reel & hydrant found nonfunctional.
2. Pump not in auto start provision.
3. Alternate exit found locked/blocked.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,  
New Delhi.