

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

No. F6/DFS/MS/SZ/2024/EH/460

Dated: 18 / 10 / 2024

To,

The Addl. Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi.

**Subject: Renewal of Fire Safety Certificate from fire safety point of view in r/o Dilli Darbar Restaurant, Located at, SS 2<sup>nd</sup> floor, Plot No-15-16, MLU, Sector – 6, Dwarka, New Delhi – 110075.**

Sir,

Please refer to online application No. 2024092114529 dated 21-09-2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 14/10/2024 in the presence of Sh. Vijay Bist from fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Hose reel hose & hydrants found nonfunctional
2. MOEFA found nonfunctional
3. Automatic sprinkler system found nonfunctional.
4. Terrace pumps found nonfunctional.
5. LPG cylinders are stored in kitchen area. The LPG cylinder must be stored outside kitchen.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)  
Director  
Delhi Fire Service

OC  
15/10/24

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, Dilli Darbar Restaurant, Located at, SS 2<sup>nd</sup> floor, Plot No-15-16, MLU, Sector – 6, Dwarka, New Delhi – 110075.