

c/8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/644

Dated: 18/10/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s **Hotel Safina** located at **722, Motor Market, Jama Masjid, Delhi - 06.**

Sir,

This has reference to online application I.D. no. 2024091814362 dated 18.09.2024 on the subject cited above. In this connection, it is to inform you that guest house was visited by the officer concerned of this department on 09.10.2024 in the presence Mohd. Absar (Owner Son) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. First aid hose reel provided but not functional.
2. CO detectors with panel and alarm system provided but not functional.
3. PA system not provided.
4. Fire pump not in auto start mode.
5. Exit signages are not adequately provided.
6. Occupancy above third floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Gang)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Manager,

M/s Hotel Safina at 722, Motor Market, Jama Masjid, Delhi - 06.