

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 462  
To

Dated: 21/10/2024

The Addl. Commissioner of Police,  
1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Sandwich Smugglers located at Shop No 158, DLF South Court Mall, A-1 District Centre, Saket Court Road, New Delhi 110017.

Sir,

This has reference to with **MHA Portal ID 2024091314237 dated 01/10/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.10.2024 in the presence of Mr. Anuj to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There is one exit door having width of 1.50 mtr against the required two exit doors having width of 1.50 mtr each.
2. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

ok e