



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-52
7/10
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/ 709

Dated: 16/10/2024

To,

The Principal,
Sarvodaya Kanya Vidyalaya
Mandoli, Delhi - 110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya located at Mandoli, Delhi - 110093.

Sir,

This has a reference to your Email dated 11/09/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/10/2024 in the presence of Mrs. Shikha Jain (Principal) & Mr. Rajpal Singh (Estate Manager) and observed that building comprised of Ground plus three upper floors (New Block)

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers are empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Manager, Sarvodaya Kanya Vidyalaya located at Mandoli, Delhi - 110093.