

c/23

75
Azadi Ka
Amrit Mahotsav



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

Dated: 11 / 10 / 2024

No. F.6/DFS/MS/School/2024/SZ/ 699

To

Dr. Ashok Kumar (Manager),
Vidya Bhawan Mahavidyalaya Sr. Sec. School,
Lodhi Estate, New Delhi-110003

Sub: **Regarding renewal of Fire Safety Certificate in r/o Vidya Bhawan Mahavidyalaya Sr. Sec. School, Lodhi Estate, New Delhi-110003**

Sir,

This has reference to your letter No. **VBM/281/2024** dated 06/09/2024 received through outdoor diary No. 6145 dated 06/09/2024. In this connection, the said school premises was inspected by the officer concerned of this department on 03/10/2024 from fire & life safety point of view in your presence. During the course of inspection, the shortcomings observed are as below.

1. Portable fire extinguishers found empty/unrefilled.
2. First-aid hose reel found provided but non-functional.
3. PA system found non-functional.
4. Terrace fire pump found non-functional.
5. Overhead water tank found empty.
6. Exit signages found removed at some places.

In view of the above, application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in the absence of requisite fire protection measures shall be at risk and responsibility of owner/occupier. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054