

C/58

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/CH/641

Dated: 16 /10/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Mandona guest house Located at 53/7, Old Rajinder Nagar, Bara bazaar Marg, New Delhi-110060.

Sir,

Please refer to online application No. 2024091214162, dated 19/09/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 14/10/2024 in the presence of Sh. Naresh Bhatia (Owner) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Ventilation system in common area found removed.
2. CO Detectors not provided.
3. Exit signage's found removed at some places.
4. The actual composition of building is Basement + Ground + 05 Upper Floors but it is not mentioned in CAF form.
5. Corridor of the 4th & 5th floor found being used for storage/labors resting room.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Manager, M/s Mandona guest house Located at 53/7, Old Rajinder Nagar, Bara bazaar Marg, New Delhi-110060.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.