

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2024/ 595
To,

Dated: 22/10/2024

Sh. Abhishek Sharma,
M/s City Centre Mall,
Community Centre, Block A,
Shalimar Bagh, New Delhi.

Sub: Inspection report in r/o M/s. City Centre Mall, Community Centre, Block-A, Shalimar Bagh, New Delhi- 110088.

Sir,

This has reference to your application received through outdoor diary no. 7056 dated 26/09/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officer concerned of this department on 07.10.2024 to see the compliance of the requisite fire safety measures. Sh. Abhishek Sharma was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Lower Basement, Upper Basement, Ground & Five upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Fire check door found removed at some places.
2. Smoke ventilation system found provided but not functional.
3. Detectors found removed at some places.
4. Sprinklers found removed at some places.
5. Exit signage's found removed at some places.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,

(Atul Garg)
Director

15/10