



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/68



No. F6/DFS/MS/WZ/2024/ 734

Dated:- 22/10/2024

To,

The Principal,  
Govt. Co-ed. Sr. Sec. School,  
JJ Colony-2, New Delhi-110041.

**Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Co-ed. Sr. Sec. School located at J.J. Colony-2, New Delhi-110041.**

Sir,

Please refer to your email dated 27/09/2024 & dated 14/10/2024, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 16/10/2024 in the presence of Sh. Om Prakesh (Principal, Evening Shift) & Sh. Mahipat (Estate Manager). During inspection, it has been observed that the school building is comprised of Ground + 03 upper floors. However, the following shortcoming has been observed:-

1. First Aid Hose Reels found non-functional.
2. Terrace pump of 450 lpm found non-functional.
3. Overhead water storage tank capacity 10000 ltrs. found reduced to 8000 ltrs.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)  
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

Handwritten signature of Atul Garg  
Date: 22/10/24  
Initials: DC